



5 WTC PART PLAN B2 LEVEL
FUEL OIL TANK ROOM

- NOTES**
1. FOR GENERAL NOTES SYMBOL LIST SEE DWG. E0-01.
 2. DISCONNECT AND REMOVE EXISTING SWITCH CORRESPONDING WIRE AND CONDUIT TO FIRST OUTLET BOX. PROVIDE WIRING IN CONDUIT AND/OR REPLACE, ALL OR MODIFY EXISTING WIRING TO MAKE EXISTING LIGHTING CIRCUIT OPERATIONAL WITH THE MODIFICATIONS AND ADDITIONS AS INDICATED.
 3. PROVIDE LIGHTING SWITCH AND CONNECT TO EXISTING LIGHTING CIRCUIT.
 4. FOR LIGHTING FIXTURE SCHEDULE SEE DRAWING E2-03.
 5. PROVIDE CONDUIT EXPLOSION PROOF SEAL FITTING AT EACH CONDUIT ENTERING THE TANK ROOM ENCLOSURE. CONDUIT SEAL SHALL BE APPLINGTON ESI TYPE.
 6. COORDINATE MODIFICATION OF EXISTING CIRCUITS TO ACCOMMODATE THESE REVISIONS TO AVOID EXTENDED INTERRUPTIONS OF SERVICE TO ADJACENT AREAS OR SYSTEM SERVED BY CIRCUITS AFFECTED.



Sheet 57 of 112

THIS DOCUMENT AUTHORITY
COPYRIGHT

CONFORMED DRAWING
08/9/80
SIGNED AND SEALED
COPY IS KEPT ON FILE

ORIGINAL SIGNED & SEALED BY
N.Y. P.E. (OR R.A.)

Joseph R. Loring
& Associates, Inc.
consulting engineers
One Pennsylvania Plaza
New York, New York 10001-2045
Tel: (212) 953-7400, Fax: (212) 953-7381

THE OFFICE OF
DAVID
ELIOT
SCHWARTZ
P.C.
100 WALL STREET, 10TH FLOOR, NEW YORK, NY 10005
TEL: (212) 406-1000, FAX: (212) 406-1001

LESLIE E. ROBERTSON
ASSOCIATES, P.L.L.C.
CONSULTING ELECTRICAL ENGINEERS
20 BAY 4TH STREET
NEW YORK, NY 10002
TEL: (212) 693-1000, FAX: (212) 693-1001

No. Date Revision Approved
Engineering Department
Design Divisions

The
World
Trade
Center

STANDBY POWER
5 WORLD TRADE CENTER

ELECTRICAL

5 WTC FUEL OIL
TANK ROOM
LIGHTING PLAN

This drawing is subject to conditions in contract
all alterations, ideas, designs and methods
therein are reserved to the authority and
may not be used without its written consent.

Designed by: M.A.R. Drawn by: Check by:

Date: 11/17/80 AS NOTED

Contract Number: WTC-945.071 Drawing Number: E3-01

